

7/31/2023

BOIL WATER NOTICE RESCIND

Beatty Water & Sanitation District

PWS I.D. # NV 0000009

The "Precautionary Boil Water Notice" issued to the residents in the area affected by the scheduled shutdown at 317 W Amargosa is rescinded, the system never lost pressure and there was constant positive pressure during installation.

Samples were collected upstream and downstream of the installation and both samples showed zero levels of coliform and e coil.

Thank you,

Signed

A handwritten signature in black ink, appearing to read 'Joel Murphy', with a large, stylized flourish at the end.

Joel Murphy

General Manager

Beatty Water and Sanitation District

775-553-2931

Date: July 31, 2024.